

# Gas Trains for Standard Gases (Natural gases / LPG) Selection Chart :

Model	Heat Value Range	Line Size	Suitable for Boilers of Capacity
CGT-40	0.60 Mkcal/ hr to 1.3 Mkcal/hr	40 NB	1 to 2 TPH
CGT-50	1.30 Mkcal/ hr to 2.00 Mkcal/hr	50 NB	2 to 3 TPH
CGT-50/65	2.00 Mkcal/ hr to 3.20 Mkcal/hr	50 / 65 NB	4 to 5 TPH
CGT-50/80	3.20 Mkcal/ hr to 4.00 Mkcal/hr	50 / 80 NB	6 TPH
CGT-80	4.00 Mkcal/ hr to 5.00 Mkcal/hr	80 NB	8 TPH
CGT-100	5.00 Mkcal/ hr to 6.30 Mkcal/hr	100 NB	10 TPH
CGT-100/150	6.30 Mkcal/ hr to 12.50 Mkcal/hr	100 / 150 NB	15 to 20 TPH